

# Zertifikat

# Certificate



Zertifikat Nr. Certificate No.  
R 50215465

Blatt Page  
0001

Ihr Zeichen Client Reference  
P.Y.

Unser Zeichen Our Reference  
01-CZY- 15046683 001

Ausstellungsdatum  
28.11.2011


Date of Issue  
(day/mo/yr)

**Genehmigungsinhaber License Holder**  
SUNCON PV Technology Ltd.  
13F, Fuyuan Commercial Building  
No.1, Lane 13, Maiyuan Rd.  
Xinan Community, Changan Town  
Dongguan, Guangdong  
P.R. China

**Fertigungsstätte Manufacturing Plant**  
SUNCON PV technology Ltd.  
Zhenan Road, Changan town  
Dongguan 523800  
P.R. China

Prüfzeichen Test Mark

Geprüft nach Tested acc. to  
EN 50521:2008



Zertifiziertes Produkt (Geräteidentifikation)  
Certified Product (Product Identification)

Lizenzentgelte - Einheit  
License Fee - Unit

Steckverbinder (Connector for Photovoltaic System) ®

Type Designation : C4B 5  
Rated Voltage : 1000VDC  
Rated Current : 30A  
Ambient Temperature : -40°C to +85°C  
Upper Limit Temperature: 100°C  
Cross Section Range : 1 x 4,0mm<sup>2</sup>  
Protection Degree : IP67  
Application Class : A

Remark: The labelling requirements acc. to EU Directive 2001/95 have to be observed for distribution within the EEA.

5

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

**TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg**  
Tel.: (+49/221)8 06 - 13 71 e-mail: cert-validity@de.tuv.com  
Fax: (+49/221)8 06 - 39 35 http://www.tuv.com/safety

Zertifizierungsstelle  
  
Dipl.-Ing. Bernd Scheirer